



- nitrogen oxides, and sulfur dioxide.
5. A Part 75 Test Program involves:
 - RM 1 for Traverse Point Selection
 - RM 2 (also 2F, 2G, 2H) for Flow Measurement
 - RM 3A for Oxygen and Carbon Dioxide Measurement
 - RM 4 for Moisture Measurement
 - RM 6A for Sulfur Dioxide Measurement
 - RM 7E for Nitrogen Oxides Measurement
 6. RM data are statistically compared and set forth in the following EPA Procedures:
 - PS 2 for Sulfur Dioxide and Nitrogen Oxides
 - PS 3 for Oxygen and Carbon Dioxide
 - PS 6 for Flow CEMS
 7. The foregoing RMs and PS are used to ensure that the data satisfy requirements set forth in the regulations.
 8. Results of the Part 75 Test Program are reported in accordance with requirements and application of the regulations.
 9. CEMS data are reported electronically to the Trade program.